

ECE 4320: Unit Commitment

Daniel K. Molzahn, Samuel Talkington

March 12, 2025


Logistics

Agenda: next 2 weeks

- Unit commitment
- State estimation (x2)

Office hours w/ me

- Project, coding, support
- Research interest chats



Source: xkcd

Recap

Last time:

- We introduced **optimal power flow**-make sure to check Prof. Molzahn's notes!
- We produced an approximation of this problem, DC optimal power flow.

Today:

- We'll extend DC optimal power flow to handle new practical challenges.
- This extension is called the **DC** *unit commitment* **problem**.

Handling multiple time periods

"Day-ahead" scheduling

- ullet In DCOPF, we found generations $m{p}_g$ for a single snapshot in time.
 - What are some potential challenges with this?
 - Large generators can take time (hours) to start up and shut down.
 - In practice, we need to schedule their generation "day-ahead".

The key ideas behind unit commitment: Questions

Unit commitment combines two key ideas:

• Key idea #1: We allow the loads to be time varying over time periods t = 1, ..., T:

$$\boldsymbol{p}_d^1, \dots, \boldsymbol{p}_d^t, \dots, \boldsymbol{p}_d^T.$$

- Q: How do we handle this?
- Key idea #2: We need to allow generators to be able to turn off and on.
 - Q: How do we handle this?

The key ideas behind unit commitment: Answers

Unit commitment combines two key ideas:

• Key idea #1: We allow the loads to be time varying over time periods t = 1, ..., T:

$$\boldsymbol{p}_d^1, \dots, \boldsymbol{p}_d^t, \dots, \boldsymbol{p}_d^T.$$

- O: How do we handle this?
- A: We need to find generator setpoints over these time periods:

$$\boldsymbol{p}_g^1, \dots, \boldsymbol{p}_g^t, \dots, \boldsymbol{p}_g^T.$$

- Key idea #2: We need to allow generators to be able to turn off and on.
 - Q: How do we handle this?
 - A: Introduce a new **binary variable** for each generator, at each time period:

$$u_i^t = \begin{cases} 1 & \text{if generator } i \text{ is on at time } t \\ 0 & \text{if generator } i \text{ is off at time } t. \end{cases}$$

Recall: DC optimal power flow approximation

DC optimal power flow approximation

$$\min_{\boldsymbol{\theta}, \boldsymbol{p}_g} \quad \sum_{i=1}^n c_i \left(p_{gi} \right)$$
s.t.
$$p_{gi} - p_{di} = \sum_{k=1}^n B_{ik} \left(\theta_i - \theta_k \right)$$

$$p_{gi}^{\min} \le p_{gi} \le p_{gi}^{\max}$$

$$-P_{ik}^{\max} \le B_{ik} \left(\theta_i - \theta_k \right) \le P_{ik}^{\max}$$

Extending DCOPF

We need to **modify and add constraints** to our DC OPF problem to handle these two key ideas!

Constraints we modify

Let's start transforming the DC OPF constraints, using our binary variables $u_i^t \in \{0,1\}$:

Example: transform generator limits

$$p_{gi}^{\min} \le p_{gi} \le p_{gi}^{\max} \qquad \stackrel{?}{ o}$$

Constraints we add

We also need to add **totally new** constraints:

- 1: Ramp rates
- 2: Minimum up time
- 3: Minimum down time
- 4: On/off status

Putting it all together: DC Unit Commitment (DCUC)

Generalizations and extensions

Other possible additions to DCUC you may see in practice:

- Start-up costs
- Shut-down costs
- Reserve requirements
- Startup/shutdown/production rates

Wait a minute, something seems fishy...

For each generator i = 1, ..., n and each time period t = 1, ..., T, we have two possible choices:

$$u_i^t \in \{0,1\}$$
.


- **Example:** Suppose we want to schedule n = 11 generators over T = 24 hours.
- How many combinations of the u_i^t 's are possible?

The estimated number of atoms in the known universe

Hint: it's about that much ↑


Aside: Mixed-Integer Linear Programming

- DCUC is a mixed-integer linear program (MILP).
- There has been a ton of progress in solving these problems in recent years!



The future: Mixed-Integer Non-linear Programming

- These days, we're making progress on mixed-integer non-linear programming, too!
- These speed-ups are more than just faster computers.
- Could you make the next breakthrough?



How to solve: Branch-and-bound

"Relax" the binaries:

$$u_i^t \in \{0,1\} \to u_i^t \in [0,1]$$
,

into continuous variables.

Branch-and-bound tree:

When we're done: Branch-and-bound

"Relax" the binaries:

$$u_i^t \in \{0,1\} \to u_i^t \in [0,1]$$
,

into continuous variables.

Termination conditions and optimality:

Thanks

Thank you so much for attending!

- Please consider giving me feedback on this brief survey!
- I would truly value your input on my teaching so I can better serve you.



17/18

Additional resources

Click the links below for useful resources on unit commitment:

- A Brief History of Linear and Mixed-Integer Programming Computation
- Tutorial slides on Unit Commitment
- Bernard Knueven, James Ostrowski, Jean-Paul Watson (2020) On Mixed-Integer Programming Formulations for the Unit Commitment Problem. INFORMS Journal on Computing 32(4):857-876.

Click the link below for one of the *latest breakthroughs* on unit commitment:

 Dominic Yang, Bernard Knueven, Jean-Paul Watson, James Ostrowski, Near-optimal solutions for day-ahead unit commitment, Electric Power Systems
 Research, Volume 234, 2024, 110678